

# THE CITY OF PANAMA CITY PROUDLY PRESENTS THE 2016 DRINKING WATER QUALITY REPORT

## We are pleased to report that our drinking water meets all federal and state requirements.

This year's Annual Water Quality Report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts made to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our surface water source is water drawn from Deer Point Reservoir. The City of Panama City purchases water from Bay County Utility Services.

The Bay County Water Treatment Plant uses a conventional treatment process consisting of coagulation, flocculation, sedimentation, filtration, pH adjustment, disinfection, fluoridation and corrosion control. The treatment process includes adding lime occasionally to provide additional alkalinity to the raw water so that it can react with the primary coagulating chemical, ferric sulfate that is added to remove particles and organics. Polymer is also added to assist in the coagulation process. Sodium Hypochlorite is added to maintain disinfection in the distribution system. The addition of zinc orthophosphate reduces the corrosiveness of the water. Fluoride, in the form of hydrofluorosilicic acid, is added as a supplement to prevent tooth decay. Lime is also added at the end of the process to increase the pH. These processes are needed to meet the drinking water standards as set by the United States Environmental Protection Agency (EPA) and the Florida Department of Environmental Protection (FDEP).

We are pleased to report that our drinking water meets all federal and state requirements. If you have any questions about this report or concerning your water utility, please contact Anna Wright, City of Panama City Laboratory Superintendent at 850-872-3194. We encourage our valued customers to be informed about their water utility. If you would like to learn more, The City of Panama City Commission holds regularly scheduled meetings on the second and fourth Tuesdays at 8:00 am.

The City of Panama City and Bay County Utility Services routinely monitor constituents in your drinking water according to Federal and State laws. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2016. Data obtained before January 1, 2016, and presented in this report are from the most recent testing done in accordance with laws, rules and regulations. All monitoring contaminants in the table were provided by the Bay County Utility Services except for copper, lead, chlorine and Stage 2 Disinfectants and Disinfection By-Products, which are provided by the City of Panama City Environmental Laboratory.

## 2016 CONTAMINANTS TABLE

### TERMS AND ABBREVIATIONS

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Contaminant Level" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum residual disinfectant level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**N/A - Not applicable**

**ND** - not detected and the substance was not found by laboratory analysis.

**NTU** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Parts per Million (ppm) or Milligrams per liter (mg/l)** - One part per million corresponds to one part by weight of analyte to one million parts by weight of the water sample.

**Parts per Billion (ppb) or Micrograms per liter(µg/l)** - One part per billion corresponds to one part by weight of analyte to one billion parts by weight of the water sample.

**Picocurie per liter (pCi/L)** - Measure of the radioactivity in water

**Treatment Technique(TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

### Microbiological Contaminants

Contaminant and Unit of Measurement	Dates of Sampling (Mo/Yr.)	MCL Violation Y/N	The Highest Single Measurement	The Lowest Monthly Percentage of Samples Meeting Regulatory Limits	MCLG	MCL	Likely Source of Contamination
Turbidity	Jan - Dec 2016	N	1.31	95.7	N/A	TT	Soil Runoff

Turbidity is a measure of cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of the filtration system. High turbidity can hinder the effectiveness of disinfectants. The Treatment Technique (TT) standard requires that 95% of the turbidity readings must be at 0.3 NTU or less.

### Radioactive Contaminants

Contaminant and Unit of Measurement	Dates of Sampling (Mo/Yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Radium 226+228 or combined Radium (pCi/l)	April 2011	N	0.8	N/A	0	5	Erosion of Natural Deposits

### Inorganic Contaminants

Contaminant and Unit of Measurement	Dates of Sampling (Mo/Yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	May 2016	N	0.0067	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	May 2016	N	0.63	N/A	4	4.0	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at optimum level of 0.7 ppm
Nickel (ppb)	May 2016	N	2.5	N/A	N/A	N/A	Pollution from mining and refining operations. Natural occurrence in soil.
Nitrate (ppm)	May 2016	N	0.097	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	May 2016	N	3.3	N/A	N/A	160	Salt water intrusion, leaching from soil

### Stage 2 Disinfectants and Disinfection By-Products

Disinfectant or Contaminant and Unit of Measurement	Dates of Sampling (Mo/Yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
*Chlorine (ppm) (Stage 1)	Jan - Dec 2016	N	1.4	0.71- 1.1	MRDLG= 4	MRDL= 4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	Jan - Dec 2016	N	36.2	4.6- 62.1	N/A	MCL = 60	By-product of drinking water disinfection
*Total Trihalomethanes (TTHM) (ppb)	Jan - Dec 2016	N	53.8	7.4- 87.7	N/A	MCL = 80	By-product of drinking water disinfection

One sample during 2016 (Gray Avenue and 1st Plaza) had a TTHM result of 87.7 ppb, which exceeds the MCL of 80 ppb. However, the system did not incur an MCL violation because all annual average results at all sites were at or below the MCL. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

### Total Organic Carbon

Contaminant and Unit of Measurement	Dates of Sampling (Mo/Yr.)	TT Violation Y/N	Lowest Running, Annual Average, Computed Quarterly, of Monthly Removal Ratios	Range of Monthly Removal Ratios	MCLG	MCL	Likely Source of Contamination
Total Organic Carbon (TOC) (ppm)	Jan - Dec 2016	N	1.67	1.00- 2.15	N/A	TT	Naturally present in the environment

### Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of Sampling (Mo/Yr.)	AL Exceeded Y/N	90 <sup>th</sup> percentile result	Number of sampling sites exceeding the AL	MCLG	AL	Likely Source of Contamination
*Copper (ppm)	Sep 2014	N	0.529	0 of 30	1.3	1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives
*Lead (tap water) (ppb)	Sep 2014	N	1.5	0 of 30	0	15	Corrosion of household plumbing systems, erosion of natural deposits

\*These contaminants were sampled by the City of Panama City. All other results were provided by Bay County Utility Services.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Panama City is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available at the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity.

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming, occurring or result from urban storm water runoff, industrial or

residential uses.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban water runoff and septic systems.

(E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In 2016, The Department of Environmental Protection performed a Source Water Assessment (SWA) on Bay County's system. The assessment was conducted to provide information about any potential source of contamination in the vicinity of our surface water intakes. The surface water system is considered to be at high risk because of the many potential sources of contamination in the assessment area.

The assessment results are available on the FDEP Source Water Assessment Program website at [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp). Or they can be obtained from Bay County Utility Services by calling 850-243-5010.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. The Cross-Connection Control (CCC) Program is any potential or actual connection between the public water supply and a source of contamination. The Cross-Connection Control Program is an organized, legally implemented program that is designed to prevent backflow from contaminating the public water supply. FDEP found that our Program was not being fully implemented. The City has been working diligently to conduct the annual testing of all backflow prevention assemblies and expects to be completed by September 2017. Additionally, portable backflow devices have been purchased by the City and are used when connected to a water supply at any of the City's lift stations.

**Thank you for allowing us to continue providing your family with clean, quality water this year. We at the City of Panama City Utilities Department and at Bay County Utility Services work continually to provide top quality water to every tap. We ask that all of our customers help us to protect our water sources, tap, which are the heart of our community, our way of life, and our children's future.**

Contact us: **City of Panama City Utilities Department**

**Administrative Office: 850-872-3191 M-F, 8:00-5:00**

**Environmental Laboratory: 850-872-3194 M-F, 7:00-3:30**

**2266 Michigan Ave. Panama City, FL 32405**